

From: Bachman, Melanie [<mailto:Melanie.Bachman@ct.gov>]
Sent: Friday, January 08, 2016 3:29 PM
To: James Morrissey
Subject: RE: Petition 1120 - Hawthorne Substation

Good afternoon, Jimmy.

Thank you for this notification. Consistent with the Council's decision on the D&M Plan for the Hawthorne substation modifications, your request for a temporary change in work hours to accommodate power equipment testing of transformers on Saturdays beginning with January 9, 2016 through February 20, 2016 is hereby approved.

Have a nice weekend.

Melanie

Melanie A. Bachman
Staff Attorney/Acting Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051
(860) 827-2951



CONFIDENTIAL INFORMATION: The information contained in this e-mail is confidential and is protected from general disclosure. If the recipient or the reader of this e-mail is not the intended recipient, or person responsible to receive this e-mail, you are requested to delete this e-mail immediately and do not disseminate or distribute or copy. If you have received this e-mail by mistake, please notify us immediately by replying to the message so that we can take appropriate action immediately and see to it that this mistake is rectified.

From: James Morrissey [<mailto:james.morrissey@uinet.com>]
Sent: Friday, January 8, 2016 3:23 PM
To: Bachman, Melanie
Subject: Petition 1120 - Hawthorne Substation

Good afternoon, Melanie:

The United Illuminating Company ("UI") respectfully requests approval, per the Development and Management Plan of Petition 1120, for an extended work-week to accommodate power equipment testing of transformers on Saturdays, beginning on January 9th and continuing through Saturday, February 20th. The work day will not exceed nine hours and the work will take place entirely within the substation yard and control room.

This work does not require heavy machinery and UI expects a very limited increase in noise at the site. Typically only 6-8 individuals will work on Saturdays.

UI requests this extended work week because the aforementioned testing can only take place when the temperature rises above 32 degrees. This severely limits when UI can perform its testing. For instance,

UI expects that no testing will be possible next week based on the current forecast. Allowing for Saturday testing will help UI to maintain its construction schedule.

Please let me know if this requested Saturday testing work is acceptable.

Thank you,

Jimmy

Jimmy Morrissey

Attorney

UIL Holdings Corporation

203.499.2864

james.morrissey@uinet.com

Disclaimer This e-mail, and any attached file(s), is intended solely for the use of the individual or entity to whom this e-mail is addressed and may contain information that is privileged, confidential or exempt from disclosure. If you are not one of the named recipient(s) or otherwise have reason to believe that you have received this message in error, please notify the sender and delete this message immediately from any computer. Any other use, retention, dissemination, retransmission, printing or copying of this e-mail or its contents (including any attached files) is strictly prohibited.

Disclaimer This e-mail, and any attached file(s), is intended solely for the use of the individual or entity to whom this e-mail is addressed and may contain information that is privileged, confidential or exempt from disclosure. If you are not one of the named recipient(s) or otherwise have reason to believe that you have received this message in error, please notify the sender and delete this message immediately from any computer. Any other use, retention, dissemination, retransmission, printing or copying of this e-mail or its contents (including any attached files) is strictly prohibited.